



State of Ohio Environment
Northeast Distr

OH8563112

KEVIN B COCHRAN DDS INC PWS

5/14/2008



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 14, 2008

RE: WAYNE COUNTY
KEVIN COCHRAN DDS PWS
TRANSIENT WATER SYSTEM
PWS ID # OH8563112
STU ID # 8561943

Dr. Kevin Cochran
Kevin Cochran DDS
131 N. Kohler
Orrville, OH 44667

CERTIFIED MAIL

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Dr. Cochran:

This letter is notification that the Kevin Cochran DDS Public Water System (PWS) has not complied with requirements issued during this Agency's last survey performed on September 5, 2007, in violation of rule 3745-81-60 of the Ohio Administrative Code. Kevin Cochran DDS was notified in correspondence dated September 26, 2007, to respond in writing no later than 45 days, with time frames for the following requirements:

- Well Head - OAC Chapter 3745-9-05(O) requires your well casing height above finished grade to be at least twelve inches. During the survey, I observed that the casing was only about 5 inches above surrounding grade.

Additionally, an overflow for your artesian well was partially buried. This overflow was designed to be far enough above grade to allow a free-fall over an air gap from the overflow to a tile that will take the excess water to a creek.

Please have the well casing extended by a professional well driller to meet this requirement and raise the overflow from the ground in order to function as intended.

- Sample Siting Plan - OAC Chapter 3745-81-21(A) requires public water systems to prepare a written coliform bacteria sample siting plan. A sample siting plan is especially useful when the person who normally samples is unavailable. It includes information on where to collect the samples, how many to collect, and what laboratory is utilized for analysis. It includes an appendix with information on proper sampling techniques and also discusses what actions are required if a sample is found to be total coliform positive.

We asked that you please create a sample siting plan and submit a copy to this office. Please maintain the plan on site for subsequent inspections.


KEVIN COCHRAN DDS PWS
MAY 14, 2008
PAGE 2

Please note that your well driller, Doug Frontz, spoke with me in January 2008 about progress being made about your well head work. Additionally, you and I spoke briefly in March 2008 about responding to the survey letter. However, I have no record about the final status of the well head, nor have we received a sample siting plan from you.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (330) 963-1194.

Sincerely,



Beth Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Ohio EPA, Central Office, DDAGW / OFAS
Wayne County Health Department