

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 15, 2011

**RE: NOTICE OF VIOLATION
GEAUGA COUNTY
KENSTON HIGH SCHOOL
NTNC WATER SYSTEM
PWS ID # OH2861658**

2873712

Mr. Robert A. Lee
17419 Snyder Road
Chagrin Falls, OH 44023

CERTIFIED MAIL

Dear Mr. Lee:

This letter is notification that the Kenston High School public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points in the distribution system.

This violation of the OAC is based upon information submitted by the Kenston High School PWS as reported on Monthly Operating Report (MOR) #5002 for the months of January – April 2011. Below is a table which indicates the reporting month and the number of days when the free chlorine residual was less than 0.2 mg/L or was not recorded.

Reporting Month	Number of days the free chlorine residual < 0.2 mg/L
January	9
February	8
March	13
April	7

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide a written explanation within 30 days of the date of this letter.

If you have any questions, please contact me directly at (330) 963-1182.

Respectfully,

Laurel Hricik
Environmental Specialist
Division of Drinking and Ground Waters

LH:ds

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Frank Novotny, Operator, 12092 SR 44, Mantua, OH 44255
Northeast District Office 330 | 963 1200
2110 East Aurora Road 330 | 487 0769 (fax)
Twinsburg, OH 44087-1924 www.epa.ohio.gov