


**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



August 11, 2011

RE: **NOTICE OF VIOLATION**
GEAUGA COUNTY
KENSTON HIGH SCHOOL
NTNC WATER SYSTEM
PWS ID # OH2861658

Mr. Robert A. Lee
17419 Snyder Rd
Chagrin Falls, OH 44023

CERTIFIED MAIL

Dear Mr. Lee:

This letter is notification that the Kenston High School public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points in the distribution system.

This violation of the OAC is based upon information submitted by the Kenston High School Public Water System (PWS) as reported on Monthly Operating Report (MOR) #5002 for the month of **June 2011**. Below is a table which indicates the reporting months and the number of days when the free chlorine residual was less than 0.2 mg/L or was not recorded.

Reporting Month	Number of days the free chlorine residual < 0.2 mg/L
January	9
February	8
March	13
April	7
May	14
June	6

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide a written explanation within 30 days of the date of this letter.

If you have any questions, please contact me directly at (330) 963-1182.

Respectfully,

Laurel Hricik
Environmental Specialist
Division of Drinking and Ground Waters

LH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Frank Novotny, Operator