



State of Ohio Environment




---

**Northeast District Office**


---

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 30, 2007

RE: CARROLL COUNTY  
VILLAGE of MALVERN WATER  
COMMUNITY WATER SYSTEM  
PWS ID. NO. 1000112  
STU ID. NO. 1053068

Ms. Deedee Wise, Water Department Administrator  
Village of Malvern, Water Plant  
410 North Carrollton Road  
P.O. Box 844  
Malvern, Ohio 44644

**NOTICE OF VIOLATION**

Dear Ms. Wise:

This office has reviewed the monthly operating reports for March 2007. The results indicate that on four occasions, exceedances of the secondary Maximum Contaminant Level (MCL) occurred. Details of these exceedances included:

<u>Date</u>	<u>Contaminant</u>	<u>Level milligrams/Liter (mg/L)</u>
March 8, 2007	Manganese	0.2
March 12, 2007	Manganese	0.168
March 20, 2007	Manganese	0.128
March 26, 2007	Manganese	0.101

The Ohio Administrative Code (OAC) Rule 3745-82-02 has set the secondary MCL for manganese at 0.05 mg/L. Be advised that the listed results are above the secondary MCL for manganese. This office is requesting you provide an explanation of why these exceedances occurred and the corrective action(s) you are taking to avoid these exceedances in the future. Submit your response to this office within thirty days of the date of this letter.

Sincerely,

Cynthia M. Petretich  
Environmental Specialist  
Division of Drinking and Ground Waters

CMP/ams

cc: Dave Evans, Ohio EPA, Central Office, DDAGW  
Nancy Glenny, Ohio EPA, NEDO, DDAGW  
Carroll County Health Department  
James Bates, Village Administrator/Water Superintendent, Malvern Village Hall

ec: Stivo Di Franco, Supervisor, Ohio EPA, NEDO, DDAGW