

Ohio
State of Ohio Environment
Northeast Dist



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 21, 2007

RE: CARROLL COUNTY
VILLAGE OF MALVERN WATER
COMMUNITY WATER SYSTEM
PWS ID. NO. 1000112
STU ID. NO. 1053068

Ms. Deedee Wise, Water Department Administrator
Village of Malvern, Water Plant
410 North Carrollton Road
P.O. Box 844
Malvern, Ohio 44644

NOTICE OF VIOLATION

Dear Ms. Wise:

This office has reviewed the monthly operating reports for February 2007. The results indicate that on two occasions, exceedances of the secondary Maximum Contaminant Level (MCL) occurred. Details of these exceedances included:

<u>Date</u>	<u>Contaminant</u>	<u>Level milligrams/Liter (mg/L)</u>
February 26, 2007	Iron	0.133
February 26, 2007	Manganese	0.109

The Ohio Administrative Code (OAC) Rule 3745-82-02 has set the secondary MCL for iron at 0.3 mg/L and for manganese at 0.05 mg/L. Be advised that the listed results are above the secondary MCL for both iron and manganese. This office is requesting you provide an explanation of why these exceedances occurred and the corrective action(s) you are taking to avoid these exceedances in the future. Submit your response to this office within 30 days of the date of this letter.

Sincerely,

Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP/ams

cc: Dave Evans, Ohio EPA, Central Office, DDAGW
Nancy Glenny, Ohio EPA, NEDO, DDAGW
Carroll County Health Department
James Bates, Village Administrator/Water Superintendent, Malvern Village Hall
ec: Stivo Di Franco, Supervisor, DDAGW, NEDO