



State of Ohio Environm

Northeast Di



\* 0 H 1 0 0 0 0 1 2 3 1 2 0 0 7 N O V \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

March 1, 2007

RE: CARROLL COUNTY  
VILLAGE of CARROLLTON  
COMMUNITY WATER SYSTEM  
PWS ID. NO. 1000012  
STU ID. NO. 1053067

Mr. Mike Leslie, Water Plant Superintendent  
Village of Carrollton, Water Plant  
80 Second Street, S.W.  
Carrollton, Ohio 44615

**NOTICE OF VIOLATION**

Dear Mr. Leslie:

This office has reviewed the monthly operating reports for January 2007. The results indicate that on one occasion, an exceedance of the secondary Maximum Contaminant Level (MCL) of pH occurred. Details of this exceedance included:

<u>Date</u>	<u>Contaminant</u>	<u>Level</u>
January 25, 2007	pH	6.93

The Ohio Administrative Code (OAC) Rule 3745-82-02 has set the secondary MCL for pH between a range of 7.0-10.5. Be advised that the listed result is below the secondary MCL range for pH. This office is requesting you provide an explanation of why this exceedance occurred and the corrective action(s) you are taking to avoid this exceedance in the future. Submit your response to this office within 30 days of the date of this letter.

Sincerely,

Cynthia M. Petretich  
Environmental Specialist  
Division of Drinking and Ground Waters

CMP/ams

cc: Dave Evans, Ohio EPA, Central Office, DDAGW  
Nancy Glenny, Ohio EPA, NEDO, DDAGW  
Carroll County Health Department  
Robert Fowler, Village Administrator

ec: Stivo DiFranco, Supervisor, Ohio EPA, NEDO, DDAGW