



State of Ohio Environmen



Northeast Dist. * 0 H 1 5 0 1 4 1 2 1 2 1 2 2 0 0 7 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 12, 2007

RE: **NOTICE OF VIOLATION**
COLUMBIANA COUNTY
VILLAGE OF LEETONIA
COMMUNITY WATER SYSTEM
PWS ID # OH1501412

Mr. Gary Phillips, Administrator
Village of Leetonia
300 East Main Street
Leetonia, OH 44431

CERTIFIED MAIL

Dear Mr. Phillips:

This letter is notification that the Village of Leetonia public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-02 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Village of Leetonia as reported on Monthly Operating Report (MOR) #5002 for the month of October. Results reported on the form indicated three (3) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by January 11, 2008. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW