



State of Ohio Environment:



Northeast District Office

* 0 H 3 8 0 1 1 1 2 8 2 2 2 0 0 7 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 22, 2007

RE: **NOTICE OF VIOLATION**
HOLMES COUNTY
CASTLE NURSING HOME
COMMUNITY WATER SYSTEM
PWS ID # OH3801112

Mr. Levi Weaver
Castle Nursing Home
434 N. Washington St.
Millersburg, OH 44654

Dear Mr. Weaver:

This letter is notification that the Castle Nursing Home public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01(B)(2) for failure to maintain of 0.2 mg/L or 1.0 mg/L combined chlorine residual measured at representative points throughout the distribution system. Additionally, Castle Nursing Home is in violation of OAC 3745-83-01(F)(1)(a)(ii) for failure to report daily distribution system residual chlorine.

This violation of the OAC is based upon information submitted by Castle Nursing Home as reported on Monthly Operating Report (MOR) #5002 for the months of May, June, and July of 2007. Results reported on the forms indicated three days each month where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual or 1.0 mg/L combined chlorine residual. Distribution system residual chlorine samples were missing for six days in May 2007, 11 days in June 2007, and 10 days in July 2007.

Please note that MORs are due no later than the 10th day of the next month as required by OAC 3745-81-31(A). If you have any questions, please contact me directly at (330) 963-1289.

Sincerely,

Wayne S. Butala, P.E.
Environmental Engineer
Division of Drinking and Ground Waters

WSB/ams

cc: Holmes County Health Department
Nancy Rice, Ohio EPA, NEDO, DDAGW