



State of Ohio Environmen

Northeast Dist.



\* 0 H 3 8 0 1 0 1 2 9 2 0 2 0 0 7 N O V \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 20, 2007

RE: HOLMES COUNTY  
VILLAGE OF NASHVILLE  
COMMUNITY WATER SYSTEM  
PWS ID # OH3801012

Ms. Lola K. Yeater, Water Clerk  
Village of Nashville  
P.O. Box 417  
Nashville, OH 44661

**Re: Monthly operating Report, August, 2007**

Dear Ms. Yeater:

This letter is in reference to our phone conversation today regarding the Monthly Operating Report (MOR) Form No. 5002 submitted by the Village of Nashville for the month of August 2007. Ohio Administrative Code (OAC) 3745-83-01(F)(1)(a)(ii) requires your water system to report daily distribution system residual chlorine. No distribution system sample results were reported on the form for the entire month. We understand that the water system operator had a medical emergency which prevented him from obtaining the samples; however, your system is required to monitor and report residual distribution system disinfectant levels each day the system is in operation.

The Village of Nashville must return to daily residual disinfectant monitoring immediately. Please note that a Notice of Violation will have to be issued if the water system does not continue this required monitoring. Please contact me at (330) 963-1289, if you have further questions. Best wishes for a speedy recovery for Mr. Messner.

Sincerely,

Wayne S. Butala  
Environmental Engineer  
Division of Drinking and Ground Waters

WSB/ams

cc: Holmes County Health Department  
Nancy Glenny, Ohio EPA, NEDO, DDAGW