

**Northeast District Office**

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 11, 2007

RE: HOLMES COUNTY
CASTLE NURSING HOMES, INC.
PWS ID # OH3801112

Mr. Levi Weaver
Castle Nursing Homes, Inc.
8067 TR 334
Millersburg, OH 44654

RE: Monthly Operating Reports - Clarification on Weekend Chlorine Sampling

Dear Mr. Weaver:

This letter is in addition to the Notice of Violation letter dated August 22, 2007. As discussed during our phone conversation today, the August 2007 Monthly operating Report (MOR) Form 5002 for Castle Nursing Homes lacked 14 days of distribution system residual chlorine sample data. You indicated that additional samples were taken, and that you would fax the results. Please report all data on Form 5002. Additional copies are enclosed for your use.

Please note that Ohio Administrative Code (OAC) 3745-83-01(G)(1) requires your water system to report distribution system residual chlorine each day that water is available to the public. This includes weekends, holidays, etc.

If you have any questions, please contact me at (330) 963-1289.

Sincerely,

A handwritten signature in black ink, appearing to read "Wayne S. Butala".

Wayne S. Butala, P.E.
Environmental Specialist 2
Division of Drinking and Ground Waters

WSB/ams

enclosures: EPA Form 5002