



State of Ohio Environmen



Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 20, 2007

RE: **NOTICE OF VIOLATION**
SUMMIT COUNTY
COUNTRY VIEW SOUTH APARTMENTS
COMMUNITY WATER SYSTEM
PWS ID # OH7707512

Mr. Joel Helms
Country View South Apartments
4977 Massillon Rd.
North Canton, OH 44720

CERTIFIED MAIL

Dear Mr. Helms:

This letter is notification that the Country View South Apartments public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-02 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based on my site visit conducted on July 30, 2007. A resident, in apartment #19A, allowed me to check the free chlorine residual from their kitchen tap. At approximately 12:20 p.m., and after letting the water run for ~5 minutes, the free residual was 0.01 mg/L and 0.05 mg/L. The minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by August 31, 2007. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Kenneth Baughman, Ohio EPA, Central Office, DDAGW
Kimberly Rhoads, Ohio EPA, Office Legal Services
Nancy Rice, Ohio EPA, NEDO, DDAGW
Stivo Di Franco, Ohio EPA, NEDO, DDAGW
Greg Bachmann, Attorney General's Office