



State of Ohio Environment



Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 19, 2007

RE: **NOTICE OF VIOLATION**  
SUMMIT COUNTY  
WATER & SEWER LLC  
COMMUNITY WATER SYSTEM  
PWS ID # OH7700712

Mr. Randy Kertesz  
Kertes Enterprises  
3439 West Brainard, Suite 260  
Woodmere, OH 44122

**CERTIFIED MAIL**

Dear Mr. Kertesz:

This letter is notification that the Water & Sewer LLC public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-02 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Water & Sewer LLC as reported on Monthly Operating Report (MOR) #5002 for the month of September 2007. Results reported on the forms indicated four (4) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by November 17, 2007. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

cc: Ohio EPA, Central Office, DDAGW-IMS