




State of Ohio Environmen



Northeast Dist... * 0 H 8 5 3 7 3 1 2 5 9 2 0 0 7 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 9, 2007

RE: WAYNE COUNTY
FRANKLIN TOWNSHIP ELEMENTARY SCHOOL
2060 E. MORELAND RD., WOOSTER, OH
NTNC WATER SYSTEM
PWS ID# 8537312
STU ID# 8559677

CERTIFIED MAIL

Mr. Dave Rice, Superintendent
Triway Local School District
3205 Shreve Rd.
Wooster, OH 44691

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Mr. Rice:

This letter is notification that the Franklin Township Elementary School PWS has not complied with requirements issued during this Agency's last survey performed on February 27, 2007, in violation of rule 3745-81-60 of the Ohio Administrative Code. Franklin Township Elementary School was notified in correspondence dated March 23, 2007 to respond in writing no later than 45 days, with time frames for:


1. OAC 3745-9-05(P) states that a well shall have a tightly sealed well cap to prevent the entrance of water, dirt, animals, insects, or other foreign matter, and it shall vent to the atmosphere. During this survey, we noted that the well cap had been badly damaged and is loose. Please have this cap replaced immediately with a gasketed, vented permanent well cap.
2. According to Ohio EPA's Backflow Prevention and Cross Connection Control guidance document, the air gap separation distance between the flood rim of the drain and the softener's discharge line should be at least twice the pipe diameter of the discharge line. This will prevent contaminated water from back-siphoning into the public water system should a vacuum occur. During the survey, we saw that the softener discharge extends below the flood rim elevation of the sewer. Please raise the discharge pipe so that you have an air gap of at least twice the discharge pipe diameter.
3. Per OAC 3745-81-21(A), total coliform monitoring must be conducted in accordance with a written sample siting plan. We have a plan on file from June 10, 2003. If any updates or changes are made, please mail a copy of your most recent sample siting plan to this office. Maintain the plan on site for subsequent inspections.

FRANKLIN TOWNSHIP ELEMENTARY SCHOOL
MAY 9, 2007
PAGE 2

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (330) 963-1194.

Sincerely,



Beth Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM:dms

pc: Wayne County Health Dept.
Dave Evans, DDAGW, CO
Vince Geiser, Triway Local School District