



State of Ohio Environment

Northeast Dist



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 31, 2007

RE: WAYNE COUNTY
HERITAGE GREEN CONDOMINIUMS - KIDRON
COMMUNITY WATER SYSTEM
PWS ID # 8562512
STU ID # 8561747

Mr. Roger Geiser
Heritage Green Condominium Association
106 Heritage Green Lane
Dalton, OH 44618

Dear Mr. Geiser:

On May 10, 2007, this office received the April 2007 Monthly Operating Report (MOR form 5002) from the Heritage Green Condominium Association. The MOR is provided as a means to relay compliance information about the operation of the water treatment plant. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Heritage Green Condominium Association treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal), and chlorine injection (disinfection), you are required to conduct monitoring for iron, manganese, and chlorine residual.

Please note the following violation:

At least one sample each month for iron and manganese is required to be analyzed by a certified laboratory. In accordance with Ohio Administrative Code (OAC) 3745-82-02, plant tap iron levels must remain at or below the secondary maximum contaminant level (MCL) of 0.3 milligram per liter (mg/L) at all times. Plant tap manganese levels must remain at or below the secondary MCL of 0.05 mg/L at all times.

On the April 2007 MOR, the iron and manganese levels were reported as summarized in the following table:

Sample Collection Date	Iron Results in mg/L	Manganese Results in mg/L
April 19, 2007	0.08	0.073

These most recent iron and manganese levels may indicate that the equipment is not operating effectively and should be adjusted immediately.

HERITAGE GREEN CONDOMINIUMS - KIDRON
MAY 31, 2007
PAGE 2

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

A handwritten signature in cursive script that reads "Beth R. Madis".

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department
Dave Evans, Ohio EPA, Central Office, DDAGW
Wayne Leichty, Heritage Green Condominium Association
Ray Steiner, Heritage Green Condominium Association
Rick Jackson