



State of Ohio Environment



Northeast Dist... *OH85010127312007NOV*

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 31, 2007

RE: WAYNE COUNTY
GLENRIDGE MHP
COMMUNITY WATER SYSTEM
PWS ID # OH8501012; STU ID # 8559598

Mr. Tom Funk
Touchdown Properties, Ltd.
4805 Munson St. NW
Canton, Ohio 44718

Dear Mr. Funk:

On July 9, 2007, this office received the May 2007 Monthly Operating Report (MOR form 5002) from Glenridge Mobile Home Park. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Glenridge treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal), ion exchange softening (hardness removal), and chlorine (disinfection) injection, you are required to conduct monitoring for iron, manganese, hardness, and chlorine residual.

Please note the following violation:

At least one sample each month for iron and manganese is required to be analyzed by a certified laboratory. In accordance with Ohio Administrative Code (OAC) 3745-82-02, plant tap iron levels must remain at or below the secondary maximum contaminant level (MCL) of 0.3 milligram per liter (mg/L) at all times. Plant tap manganese levels must remain at or below the secondary MCL of 0.05 mg/L at all times.

On the June 2007 MOR, the iron and manganese levels were reported as summarized in the following table:

Sample Collection Date	Iron Results in mg/L	Manganese Results in mg/L
June 7, 2007	0.08	0.086

This most recent manganese level may indicate that the equipment is not operating effectively and should be adjusted immediately.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis, Environmental Specialist
Division of Drinking and Ground Waters

BRM//ams

cc: Wayne County Health Department
Dave Evans, Ohio EPA, Central Office, DDAGW