



State of Ohio Environment



Northeast District Office OH 8 5 0 0 1 1 2 9 2 7 2 0 0 7 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

September 27, 2007

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: WAYNE COUNTY
VILLAGE OF APPLE CREEK
COMMUNITY WATER SYSTEM
PWS ID NO. OH8500112
STU ID NO. 8559590

Mayor Alan Miller
Village of Apple Creek
P.O. Box 208
Apple Creek, OH 44606

Dear Mayor Miller:

Monthly Operating Reports (MORs) are provided as a means to relay compliance information about the operation of the water treatment plant. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Apple Creek treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal) and chlorine injection (disinfection), you are required to conduct monitoring for iron, manganese, and chlorine residual.

Please note the following violation:

In accordance with Ohio Administrative Code (OAC) 3745-83-01(I)(2), MORs must be submitted to this office no later than the tenth of the month following the month for which the report was prepared.

We do not have the microbiological MORs for the months of June and July 2007.

Please submit copies of these forms within 10 days of this letter date. If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM:dms

pc: Wayne County Health Department
Dave Evans, DDAGW-CO
Randy Danford, Village of Apple Creek, P.O. Box 208, Apple Creek, Ohio 44606