Ohio EPA
State of Ohio Environmental Protection Agency
Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 11, 2007

RE: COLUMBIANA COUNTY
RANDI'S RAY OF SUNSHINE PWS
NON-TRANSIENT
PWS # OH1565112

Ms. Linda Fanelli
15758 Pineview Dr.
Calcutta, OH 43920

Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria

Dear Ms. Fanelli:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in October 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Be advised that this system is still on a Boil Advisory as stated in the letter dated September 20, 2007.

Actions required as a result of the above violation	
Step 1	**Within 30 days** issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: 1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) *The language in italic on the attached public notice is mandatory language and must be included as written.*
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. This should include addressing outstanding issues identified in the survey letter dated January 26, 2007 and disinfecting the well and system.
Step 3	Within ten (10) days of completing **Step 1** above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.

Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in November 2007. The current Boil Advisory may then be lifted once a series of total coliform samples are determined to be total coliform negative.

If you have any questions, please contact me at (330) 963-1293.

Sincerely,

Cynthia M. Petretich

Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Columbiana County Health Department
Nancy Glenny, Ohio EPA, NEDO, DDAGW