OhioE
State of Ohio Environmenta
Northeast Distri

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 28, 2007

RE: GEAUGA COUNTY
PEACE LUTHERAN CHURCH PWS
NON-TRANSIENT
PWS #OH2874112

Peace Lutheran Church
13536 Kinsman Road
Burton, OH 44021

Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria

Dear Sir/Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in December 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	**Within 30 days** issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: 1. Hand delivery of take home notice to students/parents; 2. Posting in conspicuous locations (restrooms, bulletin boards, etc.) *The language in italic on the attached public notice is mandatory language and must be included as written.*
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing **Step 1** above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.

Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in January 2008.

If you have any questions, please contact me at (330) 963-1121.

Sincerely,

Corey Kurjian
Environmental Specialist
Division of Drinking and Ground Waters

CK:ds

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Geauga County Health Department
Nancy Glenny, Ohio EPA, NEDO, DDAGW