



State of Ohio Environment
Northeast Distr

OH7662412

GRACE BROTHERN CHURCH-MIDDLEBRANCH

8/13/2007



* 0 H 7 6 6 2 4 1 2 8 1 3 2 0 0 7 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 13, 2007

RE: STARK COUNTY
GRACE BROTHERN
CHURCH-MIDDLEBRANCH
TRANSIENT PWS
PWS ID #OH7662412

CERTIFIED MAIL

Grace Brethren Church-Middlebranch
2911 William Street NE
P.O. Box 43
Middlebranch, OH 44652

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)

Dear Sir/Madam:

During **August 2007**, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

Actions required as a result of the above violation	
Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.

GRACE BRETHERN CHURCH-MIDDLEBRANCH
AUGUST 13, 2007
PAGE 2

Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample." It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in August 2007 .

If you have any questions, please contact Mandy Razzano at (330) 963-1269.

Sincerely,



Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR:dms

enclosures

pc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Stark County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW