




State of Ohio Environmental

Northeast District



* 0 H 7 6 4 6 5 1 2 1 1 2 0 2 0 0 7 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 20, 2007

RE: STARK COUNTY
MEADOWLAKE GOLF & SWIM
TRANSIENT NON-COMMUNITY
PWS ID # OH7646512

Messrs. Roy E. Barr and Philip Barr
dba Meadowlake Golf & Swim
Meadowlake Corporation
Meadowlake, Limited
1211 39th Street NE
Canton, OH 44714

Subject: Notice of Violation - Failure to provide adequate treatment of a surface water source.

Dear Messrs. Barr:

Your public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-81-73 for the month of October 2007, because your water system uses a source that has been designated as a surface water source and you do not provide adequate treatment. Although you have made modifications to your water well, you will continue to be in violation of OAC Rule 3745-81-73 until you obtain four consecutive quarters of total coliform negative raw water samples from the farm house well. Only then would Ohio EPA be able to designate your source as ground water.

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italics on the attached public notice is mandatory and must be included as written.</i></p>
Step 2	Initiate an Investigation and take the necessary steps to correct the problem as soon as possible.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.

[Handwritten signature]

MEADOWLAKE GOLF & SWIM
NOVEMBER 20, 2007
PAGE 2

Any questions regarding this matter should be directed to the Attorney General's Office through your attorney.

Sincerely,

A handwritten signature in cursive script, appearing to read "Nancy N. Rice".

Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Stark County Health Department
Kim Etters, Ohio EPA, NEDO, DDAGW