




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



January 28, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Burt Perkins
20017 State Route 93 South
Logan, OH 43138

Hocking County
Arcadia Acres Nursing Home
Community Public Water System
PWS ID: OH3700012

Dear Mr. Perkins:

The Arcadia Acres Nursing Home Public Water System is in violation of the Ohio Administrative Code (OAC) for failure perform daily chlorine as required by OAC Rule 3745-83-01(F)(2).

All community public water systems are required to monitor both the free and combined chlorine residuals at least once every day. Arcadia Acres failed to perform chlorine monitoring for 13 days during the month of December, 2012.

Please ensure that this monitoring is performed accordingly in the future.

If you have any questions please call me at 740-380-5207.

Sincerely,

Sarah Wallace
Environmental Engineer

SW/cb

cc: Hocking County Health Department

Edward Telle, Owner
SOROKA Telle & Assoc.
1318 East Man St
Lancaster, OH 43130

Jerry Smith, Tech Supv
Buckeye Env Serv
2303 Pike TR 126 NE
New Lexington, OH 43764