



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



March 20, 2013

Ms. Candice Van Skoyck
Otterbein-Lebanon Retreat Center
585 North State Route 741
Lebanon, Ohio 45036

**RE: WARREN COUNTY
OTTERBEIN-LEBANON RETREAT CENTER
COMMUNITY PWS
PWS ID: OH8301112
VIO ID: 8627015**

Dear Ms. Skoyck:

Subject: Rescinding Violation – TCR

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on March 13, 2013, for the monitoring period of January, 2013. The missing sample was collected on January 10, 2013, but the result was not reported until March 13, 2013.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. The sample was not reported in accordance with this rule and this is considered a reporting violation. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained.

Please ensure future sample results are submitted as required. If you have any questions, please contact me at (937) 285-6113.

Sincerely,

Mariano Haensel, M.S.
Environmental Specialist 2
Division of Drinking and Ground Waters

cc: Warren County Combined Health District

MHkbp