



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 16, 2009

RE: **HOCKING COUNTY
VALLEYVIEW ESTATES MHP
COMMUNITY WATER SYSTEM
PWS ID# 3700312**

Mark L. Anthony
15111 State Rt 664 South
Logan, OH 43138

Dear Mr. Anthony:

This letter is notification that the Valleyview Estates MHP has not complied with requirements issued during this Agency's last survey performed on January 23, 2009, in violation of rule 3745-81-60 of the Ohio Administrative Code. The Park was notified in correspondence dated February 20, 2009, to respond in writing no later than 45 days, with time frames for:

Submit either documentation of completion or a schedule stipulating the time frames in which the following activities will be performed:

- Extend the wiring conduit at the well to meet the well cap;
- Install a screen on the vent hole in the well cap;
- Update and expand the Contingency Plan to include all elements described in OAC 3745-85-01; and
- Post the public notices for two previous violations and return the verification forms to this office.

The water system must respond, in writing, within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (740) 380-5207 or via email to sarah.wallace@epa.state.oh.us.

Sincerely,

Sarah Wallace
Environmental Engineer
Division of Drinking and Ground Waters

SW/cb

cc: C.O. - DDAGW/OFAS-Dave Evans
cc: Hocking County Health Department
cc: Tracy Anthony
1410 Sheridan Dr, Apt 18E
Lancaster, OH 43130