



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 22, 2010

RE: **Hocking County
Valleyview Estates MHP
Community
3700312**

Valleyview Estates MHP
Attn: Mark Anthony
15111 SR 664 South
Logan, OH 43138

Subject: Monthly Reporting

We have reviewed your Plant Distribution Monthly Operation Reports covering the time period of October and November 2010 and have noted the following deficiencies:

- Chlorine levels were not analyzed at the plant tap and distribution system as required on 45 days over the two month period that water was produced.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Hocking Health Department
cc: **Jamie Wilkins, SEDO**