




Environmental

Pr OH3700312

VALLEYVIEW ESTATES MHP PWS

2/28/2011

Jc
M
St



February 28, 2011

RE: **Hocking County
Valleyview Estates MHP
Community
3700312**

Valleyview Estates MHP
Attn: Mark Anthony
15111 SR 664 South
Logan, OH 43138

Subject: Monthly Reporting Violations

We have reviewed your Plant Distribution Monthly Operation Reports covering the time period of January 2011 and have noted the following violations:

- Chlorine levels were not analyzed at the plant tap and distribution system as required on 23 days over the month of January.

Please take prompt action to correct these reporting violations in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: **Hocking Health Department**
cc: **Jamie Wilkins, SEDO**