



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 15, 2009

RE: **HOCKING COUNTY**
SCENIC HILLS ESTATES
COMMUNITY WATER SYSTEM
PWS #3700912

Jo Fuller, Operator
Scenic Hills Estates
14595 Bradford Dr
Logan, OH 43138

Subject: Violation for failure to maintain adequate chlorine residual

We have reviewed your Plant Distribution Monthly Operation Reports covering the time period of November 2009 and have noted the following deficiencies:

Scenic Hills Estates is in violation of OAC 3745-83-01 which states:

"All community public water systems shall maintain a minimum chlorine residual of at least two-tenths milligram per liter free chlorine or one milligram per liter combined chlorine measured at representative points throughout the distribution system."

During the month of November, Scenic Hills failed to maintain an adequate level of chlorine residual in their distribution system for eight (8) days.

Please take prompt action to correct these deficiencies in your public water supply. Continued inadequate disinfection residual violations in future reports may result in further enforcement action.

If you have any questions, feel free to call (740) 380-5207 or email to sarah.wallace@epa.state.oh.us.

Sincerely,

Sarah Wallace
Environmental Engineer
Division of Drinking and Ground Waters

SW/cb

cc: Central Office/DDAGW
cc: Hocking County Health Department
cc: **Jamie Wilkins, SEDO**