



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

March 27, 2013

Mr. Trace Meyer
Indian Village Mobile Home Park
216 West Wayne Street
Maumee, Ohio 43537-2125

Allen County
Indian Village Mobile Home Park
Community PWS
PWS ID: OH0200712

Dear Mr. Meyer:

Indian Village Mobile Home Park is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard level for iron which is 0.3 mg/L. There were two weeks during the month of February in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01(F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- (b) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.


Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Mr. Trace Meyer
March 27, 2013
Page 2

Indian Village Mobile Home Park must take immediate action to resolve these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions, please contact me at (419) 373-3007 or by e-mail at clayton.mckee@ohio.epa.gov.

Sincerely,



Clayton McKee
Division of Drinking and Ground Waters

/cg

pc: Allen County Health Department
DDAGW – NWDO

ec: Ohio Manufactured Homes Commission