



2195 Front Street  
Logan, Ohio 43138

July 10, 2007

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korfeski, Director

RE: ~~JACKSON COUNTY~~  
~~JACKSON COUNTY WATER CO~~  
~~COMMUNITY WATER SYSTEM~~  
PWS ID# 4001003 - "G"  
4001603 - "M"  
~~4001803 - "O"~~  
4001903 - "P"

Larry Foster, General Manager  
Jackson County Water Co.  
124 W. Huron Street  
PO Box 309  
Jackson, OH 45640

Dear Mr. Foster:

This office received the 2006 Consumer Confidence Report (CCR) for the various Jackson County Water Co public water systems on July 2, 2007. As submitted, the above noted Jackson County's water systems are in violation of the OAC Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. Specifically, the following deficiencies were noted:

1. None of the information from the various water sources utilized by the County was included (City of Wellston, Scioto Water, Inc or City of Jackson). The "Table of Detected Contaminants" for the four satellite systems should have included the water quality data provided by those systems to fully describe the drinking water for those customers.
2. The two surface water satellite systems ("M" and "G") were required to have notations describing the TOC and Turbidity results that should have been in the "Table".

Be sure to correct the aforementioned problems in your next CCR. The next report for calendar year 2007 must be sent to your customers no later than July 1, 2008. A copy of the CCR along with a Certification Form must be submitted to this office at the above address. Violations in future reports may result in further enforcement action.

If you have any questions or problems, please feel free to contact me at (740) 380-5207 or email me at [sarah.wallace@epa.state.oh.us](mailto:sarah.wallace@epa.state.oh.us).

Sincerely,

Sarah Wallace  
Environmental Engineer  
Division of Drinking and Ground Waters

SW/cb

cc: Jackson County Health Department