



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 1, 2008

RE: **JACKSON COUNTY  
JACKSON COUNTY WATER CO.  
COMMUNITY WATER SYSTEM  
PWS ID# 4001003 – “G”  
4001603 – “M”  
4001803 – “O”**

Larry Foster, General Manager  
Jackson County Water Co.  
124 W. Huron Street  
PO Box 309  
Jackson, OH 45640

Dear Mr. Foster:

This office received the 2007 Consumer Confidence Report (CCR) for the various Jackson County Water Co public water systems on June 30, 2007. As submitted, the above noted Jackson County's water systems are in violation of the OAC Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. Specifically, the following deficiencies were noted:

1. The two surface water satellite systems (“M” and “G”) were required to have the following notations describing the TOC and Turbidity results that were in the “Table of Detected Contaminants”:

“The value reported under “Level Found” for Total Organic Carbon (TOC) is the lowest ratio between the percentage of TOC actually removed to the percentage of TOC required to be removed. A value of greater than one (1) indicates that the water system is in compliance with TOC removal requirements. A value of less than (1) indicates a violation of the TOC removal requirements.”

“Turbidity is a measure of the cloudiness of water and is an indication of the effectiveness of our filtration system. The turbidity limit set by the EPA is 0.3 in 95% of the daily samples and shall not exceed 1 NTU at any time. As reported above, the Jackson County Water Company's highest recorded turbidity result for 2007 was \_\_\_ NTU and lowest monthly percentage of samples meeting the turbidity limit was \_\_\_%.”

2. The report for the “O” system did not include the data from any of the samples collected on that line. The lead, copper, total trihalomethane and haloacetic acid results from the “P” system were inserted instead and total chlorine was omitted entirely.

Jackson County Water Co.  
July 1, 2008  
Page 2

Be sure to correct the aforementioned problems in your next CCR. The next report for calendar year 2008 must be sent to your customers no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to this office at the above address. Violations in future reports may result in further enforcement action.

If you have any questions or problems, please feel free to contact me at (740) 380-5207 or email me at [sarah.wallace@epa.state.oh.us](mailto:sarah.wallace@epa.state.oh.us).

Sincerely,



Sarah Wallace  
Environmental Engineer  
Division of Drinking and Ground Waters

SW/cb

cc: Jackson County Health Department