



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 30, 2008

**RE: JACKSON COUNTY
CITY OF JACKSON
COMMUNITY WATER SYSTEM
PWS ID# 4000111**

City of Jackson Water Department
c/o Greg Wilson, Superintendent
145 Broadway Street
Jackson, Ohio 45640

Dear Mr. Wilson:

This office received the 2007 Consumer Confidence Report (CCR) for the City of Jackson's public water system on June 16, 2008. As submitted, Jackson's water system is in violation of the OAC Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. Specifically, the following deficiencies were noted:

- The required turbidity language was omitted: "Turbidity is a measure of the cloudiness of water and is an indication of the effectiveness of our filtration system. The turbidity limit set by the EPA is 0.3 in 95% of the daily samples and shall not exceed 1 NTU at any time. As reported above, the City of Jackson's highest recorded turbidity result for 2007 was 0.297 NTU and lowest monthly percentage of samples meeting the turbidity limits was 100%."

Be sure to correct the aforementioned problems in your next CCR. The next report for calendar year 2008 must be sent to your customers no later than July 1, 2009. A copy of the CCR along with a Certification Form must be submitted to this office at the above address. Violations in future reports may result in further enforcement action.

If you have any questions or problems, please feel free to contact me at (740) 380-5207 or email me at sarah.wallace@epa.state.oh.us.

Sincerely,

Sarah Wallace
Environmental Engineer
Division of Drinking and Ground Waters

SW/cb

cc: Jackson County Health Department