



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



March 28, 2013

Mr. Michael Richards  
Allen East Local Schools  
9105 Harding Highway  
Harrod, Ohio 45850-9485

Allen County  
Allen East Local Schools  
Non-Transient Non-Community PWS  
PWS ID: OH0254212  
VIO ID: 211

**Subject: Rescinding Violation – TCR**

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code, dated March 22, 2013, for the monitoring period of February 2013. The sample was collected on February 13, 2013 but the result was not reported until March 27, 2013.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample was not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact me at (419) 373-3089 or by e-mail at [jill.schiefer@epa.ohio.gov](mailto:jill.schiefer@epa.ohio.gov).

Sincerely,

Jill A. Schiefer  
Division of Drinking and Ground Waters

/cg

pc: Allen County Health Department  
Alloway – Lima Laboratory  
DDAGW - NWDO

