



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION

March 18, 2013

Jai Bholenath
Horizon Mart
13075 Worthington Road
Pataskala, OH 43062

Licking County
Horizon Mart PWS
TRANSIENT NON-COMMUNITY PWS
PWS ID: OH4561312

Subject: Monitoring and Reporting Violation

Dear Public Water System Owner:

The Public Water System serving HORIZON MART PWS is in violation of the Ohio Administrative Code (OAC) for failure to take a monthly "Special" Raw Water Total Coliform sample in accordance with the December 31, 2012, Sanitary Survey letter.

Violation Begin Date: 2/1/2013
Required Monitoring: 1 sample from well #1 per month
Sample Results Submitted: None

Note chlorine residual levels are required to be collected and reported on the lab sample submission sheet whenever raw samples are collected. The samples should be marked as "Special" purpose and the well identification number recorded in the comment field on the sample submission sheet.

If you have any questions please call your Ohio EPA representative at (614) 728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Water
Central District Office

ec: CDO DDAGW AA (State Violation)

CO/cf 4561312(MR)FEB2013