



Front Street
an, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 16, 2008

**RE: JEFFERSON COUNTY
WARREN WATER AUTHORITY
COMMUNITY WATER SUPPLY
PWS ID: 4102903**

Susan Kolkedy
7 Montenery Road
Rayland, OH 43943

Dear Ms. Kolkedy;

We have received and reviewed Warren Water Authority's Plant Distribution Monthly Operation Report covering the time period of March 1 - March 31, 2008 and have noted the following deficiency:

- Chlorine analyses was not performed daily in the distribution system as required by rule 3745-83-01 of the Ohio Administrative Code. If personnel are not always available, then consideration should be given to the installation of a continuous chlorine monitor.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5421.

Sincerely,

Debra Prim
Environmental Specialist
Division of Drinking and Ground Waters

DP/cb

cc: Central Office/DDAGW
cc: Jefferson County Health Department
cc: **Jamie Wilkins, SEDO**