




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



April 2, 2013

Mr. John Horman
ODOT Rest Area 7-34 WB
1001 St. Mary's Avenue
Sidney, Ohio 45365

Auglaize County
ODOT Rest Area 7-34 WB
Non-Community, Transient PWS
PWS ID: OH0634112
VIO ID: 267699

Subject: Rescinding Violation – MOR

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) dated March 26, 2013 for the monitoring period of February 2013.

The system is not taking chlorine residuals at the entry point, but because only a very short line of plumbing separates the entry point from distribution system, they are providing essentially the same information. There is a rule addendum that makes an exception for this water system. The violation has been rescinded.

If you have any questions, please contact me at 419-373-3007 or by e-mail at clayton.mckee@epa.ohio.gov.

Sincerely,

Clayton McKee
Division of Drinking and Ground Waters

/cg

pc: DDAGW - NWDO

