



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



April 2, 2013

Mr. William E. Newsome  
Aqua Ohio - Seneca  
H2O Technolgies  
P.O. Box 585  
Marion, Ohio 43301-0585

Williams County  
Aqua Ohio - Seneca  
Community PWS  
PWS ID: OH8601512

VIO ID: 8613408

**Subject: Rescinding Violation – MOR**

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC), dated March 26, 2013 for the monitoring period of February 2013.

This system did not record plant production for more than four (4) days in February. Since I have not visited this water system yet, I wasn't aware that they have a clearwell which stores finished water before distribution. This alleviates their need to produce every single day. The violation has been rescinded.

If you have any questions, please contact me at 419-373-3007 or by e-mail at [clayton.mckee@epa.ohio.gov](mailto:clayton.mckee@epa.ohio.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "Clayton McKee".

Clayton McKee  
Division of Drinking and Ground Waters

/cg

pc: DDAGW – NWDO

