



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 18, 2008

Re:

**Meigs County  
Leading Creek Conservancy  
Community Water System  
PWS ID# 5300012**

Mr. Martin Broderick, Manager  
Leading Creek Conservancy District  
34481 Corn Hollow Road  
Rutland, Ohio 45775

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that Leading Creek Conservancy District has not complied with requirements issued during this Agency's last survey performed on April 13, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. The village was notified in correspondence dated May 7, 2008, to respond in writing no later than 45 days, with time frames for:

- Ohio Revised Code (ORC) 6109.20 (B) Fluoride to be added to public water system, states the following:

"If the natural fluoride content of supplied water of a public water system is less than eight-tenths milligrams per liter of water, fluoride shall be added to such water to maintain fluoride content of not less than eight-tenths milligrams per liter of water beginning: On or before January 1, 1972, for a public water system supplying water to five thousand or more persons, but less than twenty thousand persons."

The current direct population served by Leading Creek Conservancy District is 6,194 and therefore the system must provide fluoridation to the public drinking water. Revised Detail Plans for Fluoride Addition were approved by this Agency on February 8, 2007. Those plans are valid for 5 years (until 2/8/2012). A timeline for project completion was submitted by Strand Engineers on 4/30/2007 giving a finish date of 8/15/2007. The project is now 1 year behind schedule. Please note that the new fluoride feed system will need to be inspected by our engineer prior to putting it on line.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

Leading Creek Conservancy  
August 18, 2008  
Page 2

If you have any questions, please contact me at (740) 380-5421.

Sincerely,



Debra Prim  
Environmental Specialist  
Division of Drinking and Ground Waters

DP/cb

cc: Meigs County Health Dept.  
Central Office, DDAGW  
ODH, Bureau of Oral Health Services  
Attn: Colleen Wulf  
PO Box 118  
Columbus, OH 43216-0118