



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 29, 2009

RE: MEIGS COUNTY
POMEROY VILLAGE PWS
COMMUNITY
OH5300212

VILLAGE OF POMEROY
320 E. MAIN ST.
PO BOX 666
POMEROY, OH 45769

Subject: Violation for failure to submit a properly completed required Quarterly Operating Report form 5114 and report monitoring results

A review of our records indicates that the Total Chlorine Residual Quarterly Operating Report (EPA form 5114) for the third quarter of 2009 (July, September and August) was not properly completed as required. Failure to submit this report/data constitutes a violation of the Ohio Administrative Code Rule 3745-81-31 and Section 6109.12 of the Ohio Revised Code.

All of your required monitoring data is to be maintained at the village at all times. The quarterly total chlorine residual quarterly operating report is to provide TOTAL chlorine residual values obtained when the bacteria samples are collected. Since you are required to take 3 bacteria samples per month, there should only be 3 data points per month on the form, not 30 as indicated.

The chlorine residual is recorded on the bacteria sample lab submission slip and if you failed to keep this data you need to request it from your lab.

A properly completed Total Chlorine Residual Quarterly Operating Report for the third quarter of 2009 must be submitted to this office within 30 days from the date of this letter.

If you have any questions regarding this letter, please contact me at (740) 380-5241.

Sincerely,

Debra Prim
Environmental Specialist
Division of Drinking and Ground Waters

DP/cb

cc: Central Office/DDAGW
cc: Meigs County Health Department
cc: Jamie Wilkins, SEDO