





John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Wood County  
Village Green MHP  
Community PWS  
PWS ID: OH8702412

March 11, 2013 Rescission

April 4, 2013

Ms. Ann Nightingale  
Village Green MHP  
7630 Reitz Road-Office  
Perrysburg, Ohio 43551

Dear Ms. Nightingale:

On March 11, 2013, this office issued a notice of violation to the Village Green MHP public water system that cited a violation of Ohio Administrative Code (OAC) Rule 3745-83-01 (F)(2), for failure to report free or combined chlorine residual daily at the plant tap. There were 13 days during the month in which the analysis was not performed. Donald Johnson telephoned me to discuss the appropriate response to the violation.

Previous communication from this office did not clearly indicate that analysis of free or combined chlorine residual at the plant tap had to be performed. **Therefore, our notice of violation letter dated March 11, 2013, is hereby rescinded.** However, the public water system must begin analyzing and reporting free or combined chlorine residual daily at the plant tap every day that the plant produces water.

If you have any questions, please contact me at (419) 373-3108 or by e-mail at [janis.damico@epa.state.oh.us](mailto:janis.damico@epa.state.oh.us).

Sincerely,

A handwritten signature in cursive script that reads "Janis D'Amico".

Janis D'Amico  
Division of Drinking and Ground Waters

//lr

pc: Wood County Health Department  
DDAGW – NWDO File

ec: Ohio Manufactured Homes Commission

