



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 13, 2007

Re: ~~MONROE COUNTY~~
~~MONROE WATER DISTRICT~~
~~COMMUNITY~~
OH5600812

MONROE WATER DISTRICT
43022 SIX POINTS ROAD
LAINGS, OH 43752

Subject: Minor Violation of the Consumer Confidence Report Requirements

Ohio EPA received the MONROE WATER DISTRICT Consumer Confidence Report (CCR) for 2006. The CCR was reviewed for the required content. Based on our review, the MONROE WATER DISTRICT water system is in violation of the rules 3745-96-01 through 04 of the Ohio Administrative Code for failure to comply with the CCR requirements. The following violations were noted:

- the Table of Detected Contaminants did not include the residual disinfectant information as required (the chlorine results at the time of bacteriological sample collection);
- location of wellfield was not included.

Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2007 must be sent to your customers no later than June 30, 2008. A copy of the CCR along with a Certification Form must be submitted to this office no later than July 1, 2008.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Monroe County Health Department
cc: ~~Jamie Hedges~~ SEDO