



TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 23, 2008

**RE: MORGAN COUNTY
MORGAN-MEIGSVILLE RWD
PWS ID# OH5801003
STU ID# 5856726**

Morgan-Meigsville RWD
Attn: Phil Lawrence, President
PO Box 456
McConnelsville, OH 43756

Dear Mr. Lawrence:

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of September 2008 and have noted the following deficiencies:

The chlorine residuals were not reported for three days during the month.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: C.O. - DDAGW / OFAS
cc: Morgan County Health Dept.
cc: Terry Mayle, 2440 Airport Road, McConnelsville, OH 43756