



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 29, 2010

RE: **MORGAN COUNTY  
STOCKPORT, VILLAGE OF  
COMMUNITY PUBLIC WATER SYSTEM  
PWS ID#OH5800912**

Stockport, Village of  
Attn: Village Administrator  
PO Box 158  
Stockport, OH 43787

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of March 2010 and have noted the following deficiencies:

- Chlorine levels were not analyzed in the distribution system as required on two days that water was produced.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW  
cc: Morgan County Health Department  
cc: **Jamie Wilkins, SEDO**  
cc: Mayor and Council