



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 3, 2010

RE: **MORGAN COUNTY
STOCKPORT, VILLAGE OF
COMMUNITY WATER SUPPLY
PWS ID # OH5800912**

Stockport, Village of
Attn: Treatment Plant Operator
P. O. Box 158
Stockport, OH 43787

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of January 2010 and have noted the following deficiencies:

- The chlorine residual in the distribution system was not reported for 10 days during the month, which is a monitoring and reporting violation, as per OAC 3745-83-01.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If there are any questions or concerns, please me at 740-380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: CO/DDAGW/Dave Bornino
cc: Morgan County Health Department
cc: Mayor and Council