



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

April 5, 2013

Dr. John Bondra
North Coast Orthopedics Surgery
629 Bartson Road
P.O. Box 546
Fremont, Ohio 43420

Sandusky County
North Coast Orthopedics Surgery
Transient Non-Community PWS
PWS ID: OH7258212

Dear Dr. Bondra:

The Public Water System serving North Coast Orthopedics Surgery is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that the North Coast Orthopedics Surgery PWS has not complied with requirements issued during this Agency's last survey performed on January 17, 2013, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated February 7, 2013, to respond in writing no later than 30 days, with time frames for:

1. According OAC Rule 3745-9-05 (T), "A vent shall be provided on all well caps and seals...A well vent shall be self-draining, screened with a non-corroding mesh screen of fifteen to thirty mesh, pointed downward at or above the top of the casing or pitless unit. A vent shall terminate not less than twelve inches above ground surface."

The well does not have an appropriate vent on the cap. Install a cap that meets the specifications identified in OAC 3745-9-05 (T) and includes a screened vent.

If you have any questions, please contact me at (419) 373-3108 or by e-mail at janis.damico@epa.ohio.gov.

Sincerely,

Janis D'Amico
Division of Drinking and Ground Waters

/cg

pc: DDAGW – NWDO

