



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



April 5, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Bryan S. Puder
NORW – South District
2205 U. S. Route 20 East
Norwalk, Ohio 44857

Huron County
NORW - South District
Community PWS
PWS ID: OH3946712

Dear Mr. Puder:
NORW – South District installed spray aeration in the 250,000 gallon elevated storage tank in New Washington, Ohio without receiving plan approval from Ohio EPA and is a violation of Ohio Administrative Code (OAC) 3745-91-02.

NORW – South District must submit plans for the spray aeration to Ohio EPA Northwest District Office in accordance with OAC 3745-91-02. A copy of the Ohio EPA Water Supply Data Sheet and OAC 3745-91-02 are attached.

If you have any questions, please contact me at (419) 373-4118 or by e-mail at justin.bowerman@epa.ohio.gov.

Sincerely,

A handwritten signature in cursive script that reads "Justin Bowerman".

Justin W. Bowerman
Division of Drinking and Ground Waters

//lr

pc: DDAGW, NWDO – File

ec: Paul Brock, DDAGW, NWDO
Janis D'Amico, DDAGW, NWDO
Todd Kelleher, DDAGW, CO

