



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



* D D G W O H 4 5 6 1 3 1 2 5 2 2 8 9 1 7 R E S *

April 5, 2013

Jai Bholenath
Horizon Mart PWS
13075 Worthington Road
Patalaska, OH 43062

Licking County
Horizon Mart PWS
Non-Community, Transient PWS
PWS ID: OH4561312
VIO ID: 5228917

Subject: Rescinding Violation – TCR

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on 3/18/2013 for the monitoring period of January 1, 2013. The sample was collected on January 31, 2013, but the result was not reported correctly until April 4, 2013.

The violation has been rescinded at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample was not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at 614-728-3870.

Sincerely,

Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Licking County Health Department
Benchmark Environmental Labs
District Office File

BM/ct 4561312(Rescind MR)Jan2013