



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 29, 2010

Re: **Perry County  
Village of Junction City  
Community Water System  
PWSID# 6400212**

The Honorable Ron Gleason  
Mayor, Village of Junction City  
PO Box 105  
Junction City, OH 43748

This office received the 2009 Consumer Confidence Report (CCR) for the Village of Junction City's public water system on June 25, 2010. As submitted, Junction City's water system is in violation of OAC Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. Specifically, the following violations were noted:

1. The "Table of Detected Contaminants" did not present data from the IDSE Total Trihalomethane and Haloacetic Acid samples collected in Junction City to meet the stage 2 D/DBP rule. Also, a brief explanation of the purpose of this monitoring was omitted.
2. The values reported for both the Level Found and Range of Detections for the Total Trihalomethanes and Haloacetic Acids are incorrect. Please review the methodology for calculating the running annual average located in the CCR instruction manual available on our website at <http://www.epa.ohio.gov/portals/28/documents/ccr/CCRinstructions.pdf>.
3. An explanation of the meaning of the TOC value reported was not included.

Be sure to correct the aforementioned problems in your next CCR. The next report for calendar year 2010 must be sent to your customers no later than July 1, 2011. A copy of the CCR along with a Certification Form must be submitted to this office at the above address. Violations in future reports may result in further enforcement action.

If you have any questions or problems, please feel free to contact me at (740) 380-5207 or email me at [sarah.wallace@epa.state.oh.us](mailto:sarah.wallace@epa.state.oh.us).

Sincerely,

Sarah Wallace  
Environmental Engineer  
Division of Drinking and Ground Waters

SW/cb

cc: Perry County Health Department  
cc: John Kinder, Technical Supervisor  
Kinder Environmental Services  
2112 Cherry Valley Road  
Newark, OH 43055