



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

November 16, 2009

**Re: PERRY COUNTY
VILLAGE OF NEW LEXINGTON
COMMUNITY WATER SYSTEM
PWS ID 6400411**

Village of New Lexington
c/o Scott Bryant, Administrator
125 S. Main St
New Lexington, OH 43764

We have reviewed your Monthly Operation Reports covering the time period of October 2009, and have noted the following deficiencies:

- Fluoride was outside the required range of 0.8 - 1.3 mg/L six days in the plant tap during the month of October.

Please take prompt action to correct these deficiencies in your public water supply. Continued fluoride violations in future reports may result in further enforcement action.

If you have any questions, feel free to contact me at (740) 380-5207 or via email to sarah.wallace@epa.state.oh.us.

Sincerely,

Sarah Wallace
Environmental Engineer
Division of Drinking and Ground Waters

SW/cb

cc: Perry County Health Department