



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 22, 2009

RE: **PIKE COUNTY
BEAVER
COMMUNITY WATER SUPPLY
I.D. NO. 6600012**

Village of Beaver
c/o Mayor
PO Box 238
Beaver, OH 45613

Dear Mayor:

The Village of Beaver is in violation for failure to collect daily total and free chlorine samples in the distribution system and the plant tap as required by the Ohio Administrative Code Chapter 3745-83-01. This violation, for December 2008, must be reported in your 2008 Consumer Confidence Report (CCR).

failed to collect chlorine samples from the plant tap and/or the distribution system 20 days during the month.

The above violations will remain in effect daily, until the Village of Beaver can prove that they can meet the requirements collecting samples as required.

December's monthly Bacterial results were not submitted on OEPA form 5001 as required. Computer generated forms can only be used if they are of the **same** format.

Chapter 6109 of the Ohio Revised Code (ORC) provides for civil penalties of up to \$25,000.00 per day of violation of the drinking water rules noted above. Should the Village of Beaver fail to correct its violations, Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

Thank you for your time and cooperation. If there are any questions or concerns, please call me at 740-380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: CO/DDAGW/Dave Evans
cc: Pike County Health Department
cc: Council Members
cc: Greg Wilson, 100 Pine Ridge Road, Jackson, OH 45640
cc: **Jamie Wilkins, SEDO**