



www.epa.state.oh.us

2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 17, 2008

**RE: PIKE COUNTY
BEAVER
COMMUNITY WATER SUPPLY
I.D. NO. 6600012**

Village of Beaver
c/o Mayor
PO Box 238
Beaver, OH 45613

Dear Mayor:

The Village of Beaver is in violation for failure to maintain the minimum chlorine residual in all parts of the distribution system as required by the Ohio Administrative Code Chapter 3745-83-01. This violation, for November 2008, must be reported in your 2008 Consumer Confidence Report (CCR). Chlorine levels were below the required level of 0.20 mg/l free or 1.0 mg/l combined at the plant tap and in the distribution system as follows.

out of compliance for 3 days in November 2008.

The Village of Beaver is in violation for failure to collect daily total and free chlorine samples in the distribution system and the plant tap as required by the Ohio Administrative Code Chapter 3745-83-01.

failed to collect chlorine samples from the plant tap and the distribution system 17 days during the month.


The above violations will remain in effect daily, until the Village of Beaver can prove that they can meet the requirements for minimum chlorine residuals in all parts of the distribution system and collect samples as required. Daily visits to the plant are required.

Chapter 6109 of the Ohio Revised Code (ORC) provides for civil penalties of up to \$25,000.00 per day of violation of the drinking water rules noted above. Should the Village of Beaver fail to correct its violations, Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

Village of Beaver
December 17, 2008
Page 2

Thank you for your time and cooperation. If there are any questions or concerns,
please call me at 740-380-5275.

Sincerely,



Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: CO/DDAGW/David Evans
cc: Pike County Health Department
cc: Council Members
cc: Greg Wilson, 100 Pine Ridge Road, Jackson, OH 45640
cc: Jamie Wilkins, SEDO /