



2195 Front Street
Logan, Ohio 43138

July 13, 2007

Re: ~~PIKE COUNTY~~
~~BEAVER~~
~~COMMUNITY~~
OH6600012

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

BEAVER, VILLAGE OF
6467 BEAVER PIKE ROAD
PO BOX 238
BEAVER, OH 45613

Subject: Major and Minor Violations of the Consumer Confidence Report Requirements

Ohio EPA received the Village of Beaver PWS Consumer Confidence Report (CCR) for 2006. The CCR was reviewed for the required content. Based on our review, the Village of Beaver PWS water system is in violation of rules 3745-96-01 through 04 of the Ohio Administrative Code for failure to comply with the CCR requirements. The following violations were noted:

- the Table of Detected Contaminants did not include the residual disinfectant information as required (the chlorine results at the time of bacteriological sample collection);
- data for the last five years was not included in the Table of Detected Contaminants; Nitrate 06, Chromium 04, Barium 04, TTHM 04, HAA5 04
- Monitoring and reporting violation information was not included; Bacteria, 2005 CCR, Total Chlorine report. Lead violation information was inadequate.
- required health language due to an exceedance of a level of concern was not included for the following contaminant: Lead, Required lead language is:

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2007 must be sent to your customers no later than June 30, 2008. A copy of the CCR along with a Certification Form must be submitted to this office no later than July 1, 2008.

Village of Beaver
July 13, 2007
Page 2

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Pike County Health Department
cc: ~~Jamie Hedges, SEDG~~
cc: Greg Wilson, 100 Pine Ridge Road, Jackson, OH 45640